

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-25-06-04-02

Product: EGGER AquaDura, EGGER Hybrid Flooring
thickness: 7,5 mm

Producer: EGGER Holzwerkstoffe Wismar GmbH & Co. KG
Am Haffeld 1
23970 Wismar, Germany

Order: Reaction to fire tests of floor coverings
according to EN 13501-1:2018-11

Test report: 2724636 dated 24/01/2025

Test results:

Property	Result	Declaration EN 14041:2004-02+AC:2005-05 +AC:2006-10
Reaction to fire according to EN ISO 9239-1:2010-05 Critical heat flux Smoke production	5,55 kW/m ² 20,3 % x min	Reaction to fire class* Cfl-s1
Reaction to fire according to EN ISO 11925-2:2020-02 Extent of flame ≤ 150 mm	fulfilled	

* valid on wooden subfloor or subfloors made of class A1 or A2-s1, d0 material according to EN 13238:2009-12, using adhesives or not

Dresden, 04/06/2025

R. Emsch

Head of laboratory



R. Emsch

Engineer in charge